

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No:** 7161-1576:100 Page 1 of 1

**CATEGORY:** Cables-Fire Protective Signaling

**LISTEE:** Rockbestos-Surprenant Cable Corp., 172 Sterling Street, Clinton, MA 01510  
Contact: Matthew J. Bresnahan (978) 365-6331

**DESIGN:** Type FPL, FPLR fire protective signaling cable. Also suitable for use as Circuit Integrity (CI) cable. Two conductors, No. 16 AWG cable employing Silicone Rubber insulation compound KS-502, Copper /Polyester Shield and overall Thermoplastic FRPE jacket compound KZH-638. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, NEC Art. 760 and applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, type, NEC rating and UL label.

**APPROVAL:** Listed as power-limited fire protective signaling cable.

10-04-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 13, 2002**

Listing Expires **June 30, 2003**

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**